SCOPE OF WORK

STATINTL

STATINTL

STATINTL

I. <u>General</u>

This project consists of the design and construction of a new air-conditioning system for the Facility located in Building layout and existing equipment descriptions are attached.

II. Requirements

1. A new air-cooled self-contained factory-assembled multi-zone air-conditioning unit with humidifier shall be used to service the entire building. It shall be located on the roof or on a concrete pad along-side the building. Separate thermostatically controlled zones from the unit shall be connected to each of the existing duct runs and to

the new ductwork which will serve the presently non-conditioned rooms. In lieu of a single multi-zone unit, several separate units may be used if this is determined to be a more practical 2. 100 percent back-up air-conditioning is required for rooms approach.

11 and 12A. The designer shall consider using the existing airconditioning units if any are suitable for this purpose.

- 3. Criteria to be considered in the design are set forth in the attachments to this scope of work.
- 4. All drawings and specifications for use on this project shall be prepared in accordance with applicable Navy Design, Mechanical and Electrical Handbooks, Standard Details, Design Data and Design Criteria.
- 5. It is felt that an on-site inspection will be required prior to the design of this project. Arrangements for this should be made through the
- 6. If a roof-mounted air-conditioning unit is specified, a structural analysis of the building shall be mm made to assure adequate support Approved For Release 2001/07/16: CIA-RDP78-06505A000800080035-3

of both the unit and any maintenances personnel who may be required to service the unit. The decision of where to mount the unit shall be coordinated with the Mounting the unit on a concrete pad adjacent to the building should be considered to facilitate maintenance.

- 7. If none of the existing equipment rooms are found suitable for the new equipment to be installed, the addition of a new equipment STATINTL room will be acceptable.
- 8. Upon completion of the project, a complete and accurate set of "As Built" drawings are to be submitted to the

STATINTL

9. Design drawings are to be submitted to the

for approval prior to

STATINTL

contract advertisement.

the site.

STÁTINTL

STATINTL

STATINTL

STATINTL

for all equipment, and shall be submitted to the group in the area of the site for implementation. In this regard, design drawings shall include schematic electrical and piping drawings and a suitable explanation of equipment sequence of operation. All equipment shall be specified to include installation, operating and maintenance instructions, and recommended spare parts lists. Operation and maintenance instructions for each piece of equipment, as well as for the overall system, shall be bound in book form and submitted to the

Approved For Release 2001/07/16: CIA-RDP78-06505A000800080035-3

STATINTL

- 11. All equipment used shall be of U.S. manufacture.
- 12. The design shall conform to all security requirements peculiar to the site. These shauld be ascertained during the on-site inspection mentioned above.
- 13. The design shall stipulate in the project specifications a performance test to demonstrate the capacity and proper operation of the system. Copies of the test data man shall be furnished to the
- 14. 120/208 v, 3 phase, 60 hz. power is available at the site. The design m for this project shall include all necessary electrical work for the new equipment. An analysis shall be made to assure the adequacy of available power.